ADDENDUM NO. 1

Date of Issue: 17 April 2019

To all prospective bidders of record on the Work titled: **SEWAGE LIFT STATION CONTROL PANEL UPGRADES - PROGRAMMABLE LOGIC CONTROL EQUIPMENT**

The Bid Documents are modified as follows. This Addendum is part of the Contract Documents and modifies the original documents dated March 2019.

Acknowledge receipt of this Addendum by submitting a signed copy of this addendum with the Bid. Failure to do so may subject the Bidder to disqualification.

This Addendum consists of 2 pages including this page:

CARMEL AREA WASTEWATER DISTRICT

Rachél Lather, M.S., P.E.

Signature Of Bidder To Acknowledge Receipt Of Addendum

ANSWERS TO BIDDER QUESTIONS:

Item Q-1

Q: If a shop is not within 150 miles of Carmel (Section 16600-4, 3.01, A., 1.), can the factory testing be done at the CAWD facility?

A: Yes.

CHANGES TO SECTION 0 – FRONT END DOCUMENTS-INSTRUCTIONS TO BIDDERS

REVISE: INTERPRETATION OF CONTRACT DOCUMENTS, paragraph 3 and 4 as follows:

The results of the bidding will be reported to the District Board at the next Board meeting following the bid opening at which time if bids are found to be acceptable by the District Board, written notice of award will be given to the lowest responsive and responsible Bidder. However, said District Board reserves its right to reject any or all bids, to waive irregularities of any bids or to re-advertise for all or any part of the work contemplated

No bidder shall withdraw his/her bid for a period of forty-five (45) calendar days after the date set by the Board for the opening thereof.

END OF ADDENDUM NO. 1