EMERGENCY SEWER LINE REPAIR ALERT

NO SERVICE INTERUPTION

Effected Homes:

24652 Pescadero Rd.
24680 Pescadero Rd.
24656 Pescadero Rd.

More Information:

831-917-1426

www.cawd.org

lauer@cawd.org

CARMEL AREA WASTEWATER DISTRICT
SINCE 1908

Carmel Area Wastewater District
P.O. Box 221428 Carmel California 93922 (831) 624-1248 FAX (831) 624-0811

EMERGENCY REPAIR NOTICE

What: Spot Sewer Line Repair
Where: Pescadero Road
When: 10/31/22 - 11/1/22
Why: Sewer Lateral Connection Failure
Service Interruption: None

Effected Homes:
24652 Pescadero Rd.
24680 Pescadero Rd.
24656 Pescadero Rd.

On October 26. 2022 a 2,885 gallon sewage spill occurred along the main line behind three homes located on Pescadero Road. The spill was most likely the result of significant root intrusion into the lateral and main line connections. CAWD staff immediately identified the issue and initiated our district's emergency protocol.

Representatives of CAWD and our emergency contractor will be on site beginning 10/31/22 through 11/1/22 to hand dig at these locations and complete the emergency "spot repairs". **During this time, there will be no service interruptions to the three effected homes or homes in the surrounding area.**

Please be aware of our employees, service vehicles, and equipment in the area while we complete these emergency repairs as quickly and efficiently as possible. We appreciate the community's understanding and cooperation during this period.

PLEASE NOTE:

This is the second significant spill this sewer line has experienced in the last 30 days. The entire line segment behind Pescadero Road is in very poor condition and incidents like these will continue if unresolved. These "spot repairs" are a temporary measure, but they will not solve the condition issues with this line. We continue to plan for the replacement of the existing sewer line and invite the public to continue to participate in that public process.

FOR MORE INFORMATION:

CALL: 831-917-1426 | **VISIT:** www.cawd.org | **EMAIL:** lauer@cawd.org