

ADDENDUM NO. 2

Date of Issue: 18 April 2019

To all prospective bidders of record on the Work titled: **SEWAGE LIFT STATION CONTROL PANEL UPGRADES - PROGRAMMABLE LOGIC CONTROL EQUIPMENT**

The Bid Documents are modified as follows. This Addendum is part of the Contract Documents and modifies the original documents dated March 2019.

Acknowledge receipt of this Addendum by submitting a signed copy of this addendum with the Bid. Failure to do so may subject the Bidder to disqualification.

This Addendum consists of 3 pages including this page:



CARMEL AREA WASTEWATER DISTRICT

Rachél Lather, M.S., P.E.

Signature Of Bidder To
Acknowledge Receipt Of Addendum

CHANGES TO SECTION 0 – FRONT END DOCUMENTS-

REVISE NOTICE INVITING SEALED PROPOSALS as follows:

Notice is hereby given that sealed proposals will be received by the District Board, Carmel Area Wastewater District, at the District office, 3945 Rio Road, P.O. Box 221428 Carmel, CA. 93922, until

2:00 P.M., Wednesday May 8, 2019

at which time bids will be publicly opened and read for performing the work as follows:

**SEWAGE LIFT STATION CONTROL PANEL UPGRADES-
PROGRAMMABLE LOGIC CONTROL EQUIPMENT**

CHANGES TO SECTION 161010 – ELECTRICAL GENERAL

REVISE: 1.03 QUALIFICATIONS AND REQUIRED WORK

SCOPE A. System Integrator

1. The System Integrator shall have on staff a Project Engineer with three years prior experience on similar sized projects. This Project Engineer shall coordinate the technical aspects of this project and prepare the submittals and drawings. The Project Engineer shall attend all coordination meetings when specifically requested by the Engineer.
2. The System Integrator (SI) shall meet the following minimum qualifications:
 - a. SI shall be regularly engaged providing electrical and control systems for the Municipal Water and Wastewater Industry.
 - b. SI shall have an Electrical Engineer on staff registered in the State of California as a Professional Engineer.
 - c. SI shall be capable of labeling all electrical panels as manufactured or customized by the System Integrator with appropriate UL label prior to factory testing or shipment to project site.

3. The companies listed below have been determined to meet the minimum qualifications specified in this Section and are pre-qualified for performing work as System Integrators on the project. Other System Integrators may submit a statement of qualifications, proving requirements above, and listing relevant project experience on similar completed projects. Include project references with phone numbers including the Owner, Engineer and Electrical Contractor. See submittals section of this specification section.

- a. Tesco Controls, Inc. (916) 395-8800
- b. Glenmount Global (707) 258-8400
- c. Primex Control Systems (707) 449-0341
- d. Wunderlich-Malec (925) 460-9921
- e. Telstar, Inc. (925) 671-2888
- f. TSI Controls (425) 678-4170

END OF ADDENDUM NO. 2